



Government Of West Bengal
Office Of The Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo no.:FSR/0125186211100857

Date: 15-06-2022

From:
Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services

To: EVANGEL CHARITABLE TRUST
EVANGEL PUBLIC SCHOOL, , RASUI, DAKSHIN CHATRA, P.S-BADURIA, NORTH 24 PARGANAS, PIN-743247

Sub: Fire Safety certificate of existing G+1 storied school building under group of Educational occupancy in the name & style EVANGEL CHARITABLE TRUST at RASUI, DAKSHIN CHATRA, P.S-BADURIA, NORTH 24 PARGANAS, PIN-743247

This is in reference to your application no. 0125189221100182 dated 10-06-2022 regarding the Fire Safety certificate of existing G+1 storied school building under group of Educational occupancy in the name & style EVANGEL CHARITABLE TRUST at RASUI, DAKSHIN CHATRA, P.S-BADURIA, NORTH 24 PARGANAS, PIN-743247

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the Building.
6. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and

tooperate in the event of Fire and Testing.

7.Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

8.Transformer and Switch Gear room shall be protected with automatic CO2 or D.C.P. Fire extinction confirming I.S. Specification.

9.A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.

10. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.

11.If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

12.Periodical flashing of water in the Hydrants and Sprinkler Pipe line shall be made to maintain the efficiency working performance of above mention system.

13.The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

This certificate is valid for 3 years from the date of issue and renewable after three years to be obtained from the Director General, West Bengal Fire & Emergency Services for performance of all the life & Fire Safety arrangements and installations of the building failing which this shall be revoked automatically.

Signature valid
Digitally signed by DEBTANU
BASU
Date: 2022.06.15 11:45:34 IST

Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services